

6 Conclusion

The Advanced Panel Products wall assembly met the requirements of the National Building Code of Canada Sentence 3.2.3.8 (2) when subjected to the furnace conditions of CAN/ULC S101-07, *Standard Test Methods for Fire Tests of Building Construction and Materials*.

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

INTERTEK TESTING SERVICES NA LTD.

Tested and
Reported by:



Scott Leduc, EIT
Test Engineer – Building Products

Reviewed by:



Greg Philp
Reviewer – Fire Testing